



# LOSS CONTROL

## WINTER WEATHER CHECKLIST

Facility \_\_\_\_\_ Survey by \_\_\_\_\_  
 Location \_\_\_\_\_ Date \_\_\_\_\_

### Be Prepared!

When preparing for a possible winter storm or freeze, use this checklist to minimize your facilities exposures. Instituting the following precautions, before, during and after a storm or freeze-up can help mitigate the severity of the loss as well as enhance the overall safety of the facility.

The following checklist is intended to provide our customers with the general information needed to plan and implement an adequate response to catastrophic winter weather exposures. The purpose of this form is to help protect lives, property, and other assets of the organization, and to ensure a prompt and efficient transition from emergency operations back to normalcy.

Pre-Storm Precautions	Check List
<b>General Precautions</b>	
Initiate a well-trained emergency response team and emergency action plan	Yes <input type="checkbox"/> No <input type="checkbox"/>
Designate responsibilities to ensure the plan remains in effect every year	Yes <input type="checkbox"/> No <input type="checkbox"/>
Develop a list of emergency phone numbers of weather forecasters and contractors, and appoint someone to monitor weather reports	Yes <input type="checkbox"/> No <input type="checkbox"/>
<b>Buildings</b>	
Maintain indoor temperatures above 40°F in heated areas to prevent pipe freeze-ups. Install low temperature alarms with central station response at remote buildings	Yes <input type="checkbox"/> No <input type="checkbox"/>
Ensure integrity of building shell is in good condition by closing up unnecessary openings. Ensure windows, doors, and skylights are weather-tight	Yes <input type="checkbox"/> No <input type="checkbox"/>
Inspect remote areas for possible freezing conditions and install portable heaters and thermometers if necessary. Also, install thermometers near sprinkler piping	Yes <input type="checkbox"/> No <input type="checkbox"/>
Insulate walls and investigate concealed spaces for areas lacking insulation. Consider providing temporary interior openings to allow in heat	Yes <input type="checkbox"/> No <input type="checkbox"/>
<b>Roofs</b>	
Assess your roof's capacity for excessive snow loads (roofs with elevation changes present a greater danger) and consult a professional engineer	Yes <input type="checkbox"/> No <input type="checkbox"/>
Institute a roof snow removal program for after a heavy snow to help reduce excessive snow loads and blocked roof drains from ice	Yes <input type="checkbox"/> No <input type="checkbox"/>
Monitor roof snow levels especially in areas susceptible to large drifts	Yes <input type="checkbox"/> No <input type="checkbox"/>
Clear and monitor all roofs and yard drains during storm	Yes <input type="checkbox"/> No <input type="checkbox"/>
<b>Heating Systems</b>	
Examine the entire heating system components boilers, piping, burners and controls prior to the cold weather. Repair all deficiencies	Yes <input type="checkbox"/> No <input type="checkbox"/>
For boilers: completely drain idle equipment, elevate low points or provide drain valves on condensate return lines, remove low points and dead ends, check all service lines for possible freezing, and install heat tracing around control lines transmitter boxes, and piping that carries water to the water glass	Yes <input type="checkbox"/> No <input type="checkbox"/>
Ensure heating equipment is capable of maintaining building temperatures above 40°F at the coldest point within a building (corners, eaves, or areas without heat)	Yes <input type="checkbox"/> No <input type="checkbox"/>
Schedule complete routine inspections for all space heaters to ensure operation	Yes <input type="checkbox"/> No <input type="checkbox"/>
Ensure adequate clearance is maintained between all heating equipment and combustible walls, floors, partitions, platforms, and stock	Yes <input type="checkbox"/> No <input type="checkbox"/>
<b>Fire Protection Equipment/Domestic Water Lines</b>	
Establish a procedure to ensure snow is routinely cleared away from hydrants, sprinkler control valves, smoke and heat vents, and other essential equipment, and to make sure this equipment is easily accessible	Yes <input type="checkbox"/> No <input type="checkbox"/>
Lubricate all sprinkler control valves and locks to permit ease of operation	Yes <input type="checkbox"/> No <input type="checkbox"/>
Label location of outside sprinkler control valves and hydrants for easy visibility	Yes <input type="checkbox"/> No <input type="checkbox"/>
Convert any wet pipe systems in unheated areas to dry or anti-freeze systems	Yes <input type="checkbox"/> No <input type="checkbox"/>
For dry systems: maintain all dry valve rooms above 40°F, insulate enclosure or provide portable heaters if necessary. Check pitch of piping and drain all low points and auxiliary drains	Yes <input type="checkbox"/> No <input type="checkbox"/>
Make sure fire pump room is properly heated and the system is operational	Yes <input type="checkbox"/> No <input type="checkbox"/>
Inspect all gravity tanks for leaks (ice accumulation can create risk of collapse)	Yes <input type="checkbox"/> No <input type="checkbox"/>
Check the water temperature of the fire pump suction tank or gravity tank daily. The tank temperature should be kept above 40°F	Yes <input type="checkbox"/> No <input type="checkbox"/>



# LOSS CONTROL

## WINTER WEATHER CHECKLIST - *continued*

Pre-Storm Precautions	Check List
Shut and drain "close-in-winter" systems or convert to anti-freeze systems	Yes <input type="checkbox"/> No <input type="checkbox"/>
Check the specific gravity of all existing anti-freeze systems to see if more concentrate is needed	Yes <input type="checkbox"/> No <input type="checkbox"/>
All wet pipe standpipe systems with piping located in areas subject to freezing should be shut off, drained and tagged	Yes <input type="checkbox"/> No <input type="checkbox"/>
Connections to all water motor gongs should be properly drained to prevent freezing	Yes <input type="checkbox"/> No <input type="checkbox"/>
Use a fire protection impairment kit when shutting off fire protection systems for maintenance	Yes <input type="checkbox"/> No <input type="checkbox"/>
Insulate water supply, drain, and condensate lines susceptible to freezing (near doorways, uninsulated outside walls, or adjacent to open windows) or provide UL listed heat trace insulate	Yes <input type="checkbox"/> No <input type="checkbox"/>
Remove all hoses from outside water faucets and install "frost-proof" self-draining type faucets or isolated indoors and opened to drain	Yes <input type="checkbox"/> No <input type="checkbox"/>
<b>Miscellaneous Maintenance</b>	
Provide adequate heat for water-cooled equipment	Yes <input type="checkbox"/> No <input type="checkbox"/>
Use lubricants on low-temperature applications in equipment such as pumps, blowers and compressors, in areas subjected to freezing temperatures	Yes <input type="checkbox"/> No <input type="checkbox"/>
Remove water from oil coolers and water jackets, and drain condensers of chilling units for air conditioning	Yes <input type="checkbox"/> No <input type="checkbox"/>
Check pressure vessel vents, relief valves and safety valves to assure moving parts are functional	Yes <input type="checkbox"/> No <input type="checkbox"/>
Construct wind breaks for piping and instruments subjected to low wind chills	Yes <input type="checkbox"/> No <input type="checkbox"/>
Verify adequate fuel supplies in the event of a large storm, particularly with oil-fired equipment	Yes <input type="checkbox"/> No <input type="checkbox"/>
Establish a reserve fuel supply equal to the normal supply, or provide a safe alternate fuel source for sufficient duration	Yes <input type="checkbox"/> No <input type="checkbox"/>
Develop an emergency contingency plan if the surrounding area is impassable	Yes <input type="checkbox"/> No <input type="checkbox"/>
Contact manufacturers and contractors of critical machinery to establish a contract for priority support with backups	Yes <input type="checkbox"/> No <input type="checkbox"/>
Ensure data processing software, files, records, etc. been properly backed up and transported off-site	Yes <input type="checkbox"/> No <input type="checkbox"/>
Contact PIC Claims for adjusting and related services	Yes <input type="checkbox"/> No <input type="checkbox"/>
<b>Post-Storm Precautions</b>	
<b>Initiate salvage activities immediately, including</b>	
Secure site and assess damage	Yes <input type="checkbox"/> No <input type="checkbox"/>
Implement the action plan for the storm emergency team	Yes <input type="checkbox"/> No <input type="checkbox"/>
Institute the emergency repair program with utility contractors after loss of electric or gas power, telephone services, or public water supply	Yes <input type="checkbox"/> No <input type="checkbox"/>
Return all fire protection systems to service as soon as possible	Yes <input type="checkbox"/> No <input type="checkbox"/>
Look for live down power lines	Yes <input type="checkbox"/> No <input type="checkbox"/>
Look for structures in danger of collapse	Yes <input type="checkbox"/> No <input type="checkbox"/>
Separate damaged materials from undamaged materials	Yes <input type="checkbox"/> No <input type="checkbox"/>

Signed \_\_\_\_\_ Dated \_\_\_\_\_

Additional Comments \_\_\_\_\_

800.873.4552

The information and suggestions presented by Philadelphia Indemnity Insurance Company in this e-brochure is for your consideration in your loss prevention efforts. They are not intended to be complete or definitive in identifying all hazards associated with your business, preventing workplace accidents, or complying with any safety related, or other, laws or regulations. You are encouraged to alter them to fit the specific hazards of your business and to have your legal counsel review all of your plans and company policies. © 2010 Philadelphia Insurance Companies



PHLY.com

